



# Memorandum

CITY OF HENDERSON

240 Water Street

P.O. Box 95050

Henderson, NV 89009-5050

DEPT. OF UTILITY SERVICES

Priscilla Howell, Director

702-267-2500

fax 702-267-2501

TO: See Distribution

FROM: Akash Sehdev, P.E., Utility Services Engineer II

DATE: November 15, 2016

SUBJECT: Approved Materials List – Meter Box Lids

*Akash Sehdev*


The City of Henderson has recently started using a new automatic meter reading sensor that has different dimensions than the touch reading sensor. To accommodate the new and the old meter sensors, the sensor hole for the meter box lids must be modified.

The dimensions for the sensor hole for the new meter box lids are as follow:

- 4 5/8" x 3/8" Recess with 2" x 2 3/4" Hole  
(Please refer to Figure 1 for reference)

Effective January 3, 2017, the City will require all meter box lids to accommodate the new and the old touch read meter sensors. Current meter box lids on the Approved Materials List will not be accepted.

Vendors and manufacture can submit Approved Materials List application for the meter box lids that meet the new dimension requirements.



If you have any questions or comments, please contact me at (702) 267-2543.

AS:an

Distribution:

Dana Kepner Company, Inc.

DFW Plastics, Inc.

Ferguson Waterworks

HD Supply Waterworks

cc: Cody Dennett, Field Operations Manager

Lance Olson, P.E., Quality Control Manager

Jorge Pardiñas, Meter Services Manager

Donald E. Pelissier, P.E., Utility Services Infrastructure Planning Manager

Tim Kelley, Unit Supervisor Water Operations