



**Keeping our RASEM Members informed during these changing times is something we take seriously.**

**Dear RASEM Members:**

Edwards, a manufacturer of residential and commercial fire detection and alarm devices, in conjunction with the U.S. Consumer Product Safety Commission (CPSC), has announced a recall of certain heat detectors, sold from January 1979 through May 2018, due to a failure to activate in reaction to rising temperatures, posing a risk of failure to alert consumers to a fire.

This recall involves mechanical heat detectors used indoors to detect elevated temperatures as part of professionally installed fire detection systems for residential homes and businesses. In residential settings, this product is installed in kitchens, attics and garages for property protection. The recalled heat detectors do not detect smoke or make an audible sound, but rather act as sensors that trigger fire alarms or security panels when elevated heat is detected. The heat detectors can be mounted to walls or ceilings and are labeled with "135F" and "NOT A LIFE SAFETY DEVICE."

For more information, [CLICK HERE](#) to go to the Massachusetts State Fire Marshal's Official Memo.

**Consumer Contact:**

Edwards Fire Safety at 800-505-5088 from 9 a.m. to 5 p.m. ET Monday to Friday, or online at <https://edwardsfiresafety.com> and click on "Mechanical Heat Detector Information" for more information, or at <https://edwardsheatdetector.rsvpcomm.com>

[Visit Our Website](#)

