

The Energy Network Home Upgrade Program Technical Specifications

Choose three or more measures to qualify for an Energy Upgrade California® Home Upgrade rebate.

	Upgrade Measure	Technical Specifications	Rebate Amount
Base Measures	Whole Building Air Sealing	≥ 15% leakage reduction from the defaults or test-in CFM 50 result	\$250
		≥ 30% leakage reduction from the defaults or test-in CFM 50 result	\$450
	Attic Insulation & Attic Plane Sealing	Insulate ≥ R-38	\$550
		Insulate ≥ R-44	\$650
	Duct Sealing	Seal ≤ 10%	\$250
		Seal ≤ 6%	\$650
	* BASE MEASURE BONUS	Total of two base measures	Add \$150 to existing total
		Total of three base measures	Add \$350 to existing total
Heating & Cooling	Duct Insulation	Insulate ≥ R-8	\$400
	Central Air Conditioner	≥ 15 SEER	\$750
	Furnace	Central Furnace ≥ 92% AFUE	\$600
		Central Furnace ≥ 95% AFUE	\$700
		Wall Furnace ≥ 70% AFUE	\$400
Building Shell	Windows	U-Factor ≤ 0.30 and SHGC ≤ 0.25	\$700
	Wall Insulation	Insulate ≥ R-13 for 2x4 frame	\$500
		Insulate ≥ R-19 for 2x6 frame	
	Floor Insulation	Insulate ≥ R-19	\$550
Water Heating	Water Heater	Gas Storage Water Heater EF ≥ 0.67	\$350
		Gas Storage Water Heater EF ≥ 0.70	\$450
		Gas Tankless Water Heater EF ≥ 0.82	\$900
		Electric Water Heater EF ≥ 2.00	\$400

Additional Requirements

Description
A carbon monoxide detector must be present or installed on each floor.
Testing must be performed after work is completed to ensure quality and occupant safety.
The home must have a minimum of 10% energy savings or measure rebate value of \$2,000 or greater.
Rebate and incentive amount can be a maximum of 50% of the total project cost, up to a \$3,000 cap.
Projects that include central air conditioning or a heat pump, or their related fans, must submit proof of permit closure.