

Code: 90149-8

(only used for non- isolated)

Features:

- Listed for field installation-UL924 and CSA C22.2 NO.141
- Selectable emergency power 3W,5W,8W
- Universal input (100-277Vac)
- Battery protections: over voltage protection, low voltage protection, over temperature protection
- RoHS compliant

Specifications

UL Listed

For field or factory installation



Universal Input Voltage

100-277Vac, 50/60Hz

AC Input Current

90mA max.

AC Input Power Rating

6W max.

Output Current and Voltage

400mA 95Vdc max.

Output Power

8W max.

Illumination Time

≥90 Minutes

Full Warranty

5 Years

Test Switch/Charging Indicator Light

Low Voltage, illuminated Test Switch

Battery

High-Temperature, Maintenance-Free Ni-MH battery

5 Years Life Expectancy

Battery Charging Current

250mA

Recharge Time

≥24Hours

Temperature Rating (Ambient)

0°C to +50°C (32°F to 122°F)

Dimensions


9.25"x1.97"x1.8" (235mmx50mmx46mm)

17.7" (450mm) Flexible Conduit

Weight

2.64 lbs(1.2kg)

Wiring Diagram:



1. DO NOT MATE CONNECTOR UNTIL INSTALLATION IS COMPLETE AND AC POWER IS SUPPLIED.
2. TEST ACCESSORY LEADS-OBSERVE PROPER POLARITY WIRING.

Dimensions:

Case-9.25"X1.97"X1.8"(mounting center-8.62")



Emergency LED Driver IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS.

- Risk of fire or electric shock. Luminaire wiring and electrical parts may be damaged when drilling for installation of LED Emergency Backup. Check for enclosed wiring and components.
- Risk of fire or electric shock. This LED Emergency Backup installation requires knowledge of luminaires electrical systems. If not qualified, do not attempt installation. Contact a qualified electrician.
- Before installing, make certain the AC power to the fixture is off.
- The electrical rating of this product is 100–277Vac. Installer must confirm that there is 100–277Vac the fixture before installation.
- To prevent electrical shock, only mate unit connector after installation is complete and before the AC power to the fixture is back on.
- Do not use outdoors.
- This LED Emergency Backup unit requires an un-switched AC power source of 100–277Vac, 50/60Hz. The AC driver must be on the same branch circuit as the LED Emergency Backup unit.
- Do not let power supply cords touch hot surfaces.
- Do not mount near gas or electric heaters.
- Do not join battery pack connector until all other wiring is complete and AC power is on.
- Equipment should be mounted in locations and at heights where it will not be subjected to tampering by unauthorized personnel.
- The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition.
- Do not use this equipment for other than its intended use.
- Use with grounded, UL Listed, dry or damp location rated fixtures.

SAVE THESE INSTRUCTIONS

Applications

The BLD-AM08N-950400 emergency driver for product with internal driver. The BLD-AM08N-950400 can supply an LED lighting load of 8w for 90 minutes. These emergency driver have been evaluated to and found compliant to UL 924. The emergency pack assembly is accepted as a component of a luminaire where the suitability of the combination shall be determined by UL or Authorities Having Jurisdiction. The as-installed performance of the system must meet or exceed all Federal, State, and Local code requirements.

Operation

AC Operation : AC power is present. The AC driver operates the LED load as designed. AC internal driver that has an input current not to exceed 2.0 A. The emergency pack is charging in a standby mode. The charging indicator will be lit, showing that the battery is charging.

Emergency Operation : When the AC power goes out, the emergency pack detects the power outage and automatically switches to the emergency mode. The charging indicator will be off. The LED load is illuminated, for a minimum of 90 minutes. When AC power is restored, The emergency pack switches back to Normal Mode and starts re-charging.

Manlfuction Mode: When the emergency driver internal circuit without fault and battery normal, The green LED will be lit, When battery disconnected and the emergency driver circuit fault, the green LED off.

Dial switch code selection

Emergency Power			
Power	Voltage	1	2
8W	95vdc	—	—
5W		—	ON
3W		ON	—

NOTE : When the dial switch code 1 and 2 turn off, the emergency power is 8 W, 1 turn off and 2 turn on, the emergency power is 5W, 1 turn on and 2 turn off, the emergency power is 3W.