WILTON MANORS, *Island City*
2020 WILTON DRIVE, WILTON MANORS, FLORIDA 33305

Life's Just Better Here

EMERGENCY MANAGEMENT/UTILITIES
(954) 390-2190
FAX: (954) 567-4212

Sanitary Sewer Overflow and Water Quality Advisory

On November 18th, 2026, The City experienced intense rainfall that caused street flooding as the stormwater system reached capacity.

Following the rainfall, wastewater flows increased significantly due to infiltration and inflow (I&I). Beginning at approximately 7:00 a.m. on November 18, 2026, City crews reported sanitary sewer overflows (SSOs) resulting from system surcharging at the intersection of NE 5th Avenue and NE 21st Court and at the intersection of NE 26th Street and North Andrews Avenue. City staff responded to both locations and took measures to contain the overflows.

The overflow at NE 26th Street and North Andrews Avenue entered the North Fork of the Middle River through a stormwater outfall near the North Andrews Avenue bridge. The overflow near 2124 NE 5th Avenue entered the South Fork of the Middle River through a stormwater outfall near the Wilton Drive bridge.

A precautionary water quality advisory is in effect for the South Fork of the Middle River and adjacent canals. Residents and visitors should avoid all recreational water activities in these areas until further notice. This includes swimming, fishing, jet skiing, boating, and other activities involving contact with the water.

Water quality sampling is underway both upstream and downstream of the discharge points; the advisory will be lifted once satisfactory test results are obtained.

While SSO response activities continue, the following road closures will remain in effect until further notice:

- NE 26th Street at North Andrews Avenue — Only the westbound lane turning north onto Andrews Avenue.
- NE 5th Avenue between NE 21st Court and NE 22nd Street.

We appreciate your understanding and cooperation.

