

**Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2025 (10/01/2024 - 09/30/2025)**

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0920 - Electrical Equipment - Power Cords and Extens	74
0321 - Hazardous Areas - Enclosure	47
0372 - Subdivision of Building Spaces - Smoke Barrier	47
0353 - Sprinkler System - Maintenance and Testing	45
0363 - Corridor - Doors	39
0324 - Cooking Facilities	32
0921 - Electrical Equipment - Testing and Maintenance	31
0923 - Gas Equipment - Cylinder and Container Storag	31
0351 - Sprinkler System - Installation	30
0918 - Electrical Systems - Essential Electrical Systems	28