Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2026 (10/01/2025 - 09/30/2026)

FED - K - LSC 2012 Health Existing

Tag	# of Citations
0920 - Electrical Equipment - Power Cords and Extens	70
0353 - Sprinkler System - Maintenance and Testing	57
0372 - Subdivision of Building Spaces - Smoke Barrier	51
0363 - Corridor - Doors	32
0321 - Hazardous Areas - Enclosure	30
0918 - Electrical Systems - Essential Electrical System	30
0712 - Fire Drills	21
0351 - Sprinkler System - Installation	20
0916 - Electrical Systems - Essential Electrical System	20
0900 - Health Care Faciltiies Code - Other	19