

**Kentucky - Office of Inspector General
 Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
 During FFY 2025 (10/01/2024 - 09/30/2025)**

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0920 - Electrical Equipment - Power Cords and Extens	15
0372 - Subdivision of Building Spaces - Smoke Barrier	14
0363 - Corridor - Doors	13
0324 - Cooking Facilities	12
0351 - Sprinkler System - Installation	12
0353 - Sprinkler System - Maintenance and Testing	11
0921 - Electrical Equipment - Testing and Maintenance	11
0321 - Hazardous Areas - Enclosure	10
0923 - Gas Equipment - Cylinder and Container Storage	10
0712 - Fire Drills	8