

**Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2020 (10/01/2019 - 09/30/2020)**

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0353 - Sprinkler System - Maintenance and Testing	32
0321 - Hazardous Areas - Enclosure	23
0363 - Corridor - Doors	20
0920 - Electrical Equipment - Power Cords and Extens	16
0374 - Subdivision of Building Spaces - Smoke Barrier Doors	15
0222 - Egress Doors	13
0741 - Smoking Regulations	12
0923 - Gas Equipment - Cylinder and Container Storage	12
0232 - Aisle, Corridor, or Ramp Width	11
0372 - Subdivision of Building Spaces - Smoke Barrier Construction	11