

**Kentucky - Office of Inspector General  
 Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes  
 During FFY 2024 (10/01/2023 - 09/30/2024)**

**FED - K307 - K - LSC 2012 Health Existing (03.03)**

| Tag  | # of Citations |
|--|----------------|
| 0372 - Subdivision of Building Spaces - Smoke Barrier Construction | 12             |
| 0920 - Electrical Equipment - Power Cords and Extension Cords      | 12             |
| 0353 - Sprinkler Systems - Maintenance and Testing                 | 10             |
| 0321 - Hazardous Areas - Enclosure                                 | 9              |
| 0918 - Electrical Systems - Essential Electrical System            | 9              |
| 0363 - Corridor - Doors  | 8              |
| 0351 - Sprinkler System - Installation                             | 7              |
| 0912 - Electrical Systems - Receptacles                            | 6              |
| 0225 - Stairways and Smokeproof Enclosures                         | 5              |
| 0374 - Subdivision of Building Spaces - Smoke Barrier Doors        | 5              |