

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2019 (10/01/2018 - 09/30/2019)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0363 - Corridor - Doors	18
0372 - Subdivision of Building Spaces - Smoke Barrier	15
0353 - Sprinkler System - Maintenance and Testing	13
0361 - Corridors - Areas Open to Corridor	12
0918 - Electrical Systems - Essential Electric Systems	9
0211 - Means of Egress - General	6
0321 - Hazardous Areas	6
0374 - Subdivision of Building Spaces - Smoke Barrier	5
0351 - Sprinkler System - Installation	5
0345 - Fire Alarm System - Testing and Maintenance	4