

**Kentucky - Office of Inspector General  
 Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes  
 During FFY 2020 (10/01/2019 - 09/30/2020)**

**FED - K307 - K - LSC 2012 Health Existing (03.03)**

Tag	# of Citations
<b>0353 - Sprinkler System - Maintenance and Testing</b>	33
<b>0321 - Hazardous Areas - Enclosure</b>	24
<b>0363 - Corridor - Doors</b>	21
<b>0920 - Electrical Equipment - Power Cords and Extens</b>	18
<b>0374 - Subdivision of Building Spaces - Smoke Barrie</b>	16
<b>0923 - Gas Equipment - Cylinder and Container Storage</b>	14
<b>0222 - Egress Doors</b>	13
<b>0232 - Aisle, Corridor, or Ramp Width</b>	12
<b>0372 - Subdivision of Building Spaces - Smoke Barrier Construction</b>	12
<b>0741 - Smoking Regulations</b>	12