

**Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2025 (10/01/2024 - 09/30/2025)**

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0363 - Corridor - Doors	8
0920 - Electrical Equipment - Power Cords and Extension Cords	7
0324 - Cooking Facilities	6
0372 - Subdivision of Building Spaces - Smoke Barrier Construction	6
0712 - Fire Drills	6
0921 - Electrical Equipment - Testing and Maintenance	6
0351 - Sprinkler System - Installation	4
0914 - Electrical Systems - Maintenance and Testing	4
0923 - Gas Equipment - Cylinder and Container Storage	4
0293 - Exit Signage	3