

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2019 (10/01/2018 - 09/30/2019)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0363 - Corridor - Doors	28
0353 - Sprinkler System - Maintenance and Testing	22
0372 - Subdivision of Building Spaces - Smoke Barrier	18
0361 - Corridors - Areas Open to Corridor	17
0918 - Electrical Systems - Essential Electric Systems	10
0321 - Hazardous Areas	8
0374 - Subdivision of Building Spaces - Smoke Barrie	8
0232 - Aisle, Corridor, or Ramp Width	7
0920 - Electrical Equipment - Power Cords and Extens	7
0712 - Fire Drills	7
0345 - Fire Alarm System - Testing and Maintenance	7