

**Kentucky - Office of Inspector General  
 Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes  
 During FFY 2024 (10/01/2023 - 09/30/2024)**

**FED - K307 - K - LSC 2012 Health Existing (03.03)**

Tag	# of Citations
0920 - Electrical Equipment - Power Cords and Extension Cords	32
0372 - Subdivision of Building Spaces - Smoke Barrier Construction	31
0918 - Electrical Systems - Essential Electrical System	27
0321 - Hazardous Areas - Enclosure	24
0351 - Sprinkler System - Installation	21
0353 - Sprinkler Systems - Maintenance and Testing	20
0921 - Electrical Equipment - Testing and Maintenance	17
0363 - Corridor - Doors	16
0912 - Electrical Systems - Receptacles	15
0712 - Fire Drills	14