

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2019 (10/01/2018 - 09/30/2019)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0363 - Corridor - Doors	37
0353 - Sprinkler System - Maintenance and Testing	36
0372 - Subdivision of Building Spaces - Smoke Barrier	22
0361 - Corridors - Areas Open to Corridor	18
0918 - Electrical Systems - Essential Electric Systems	13
0374 - Subdivision of Building Spaces - Smoke Barrie	13
0321 - Hazardous Areas	11
0712 - Fire Drills	11
0511 - Utilities - Gas and Electric	9
0232 - Aisle, Corridor, or Ramp Width	9