

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2023 (10/01/2022 - 09/30/2023)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0321 - Hazardous Areas - Enclosure	19
0372 - Subdivision of Building Spaces - Smoke Barriers	16
0918 - Electrical Systems - Essential Electrical System	14
0920 - Electrical Equipment - Power Cords and Extens	12
0363 - Corridor - Doors	9
0353 - Sprinkler System - Maintenance and Testing	8
0222 - Egress Doors	7
0374 - Subdivision of Building Spaces - Smoke Barrie	7
0914 - Electrical Systems - Maintenance and Testing	6
0712 - Fire Drills	6