

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2020 (10/01/2020 - 09/30/2021)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0741 - Smoking Regulations	10
0321 - Hazardous Areas - Enclosure	8
0363 - Corridor - Doors	7
0511 - Utilities - Gas and Electric	7
0781 - Portable Space Heaters	7
0353 - Sprinkler System - Maintenance and Testing	6
0911 - Electrical Systems - Other	6
0923 - Gas Equipment - Cylinder and Container Storage	6
0271 - Discharge from Exits	4
0355 - Portable Fire Extinguishers	4