

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2024 (10/01/2023 - 09/30/2024)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0353 - Sprinkler Systems - Maintenance and Testing	6
0372 - Subdivision of Building Spaces - Smoke Barrie	5
0918 - Electrical Systems - Essential Eelectrical System	5
0920 - Electrical Equipment - Power Cords and Extens	5
0225 - Stairways and Smokeproof Enclosures	4
0363 - Corridor - Doors	4
0291 - Emergency Lighting	3
0325 - Alcohol Based	2
0511 - Utilities - Gas and Electric	2
0781 - Portable Space Heaters	2