

Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2018 (10/01/2017 - 09/30/2018)

FED - K307 - K - LSC 2012 Health Existing (03.02)

Tag	# of Citations
0322 - Laboratories	11
0355 - Portable Fire Extinguishers	6
0353 - Sprinkler System - Maintenance and Testing	5
0211 - Means of Egress - General	5
0321 - Hazardous Areas - Enclosure	5
0372 - Subdivision of Building Spaces - Smoke Barrier	4
0923 - Gas Equipment - Cylinder and Container Storag	4
0918 - Electrical Systems - Essential Electric Syste	4
0222 - Egress Doors	2
0223 - Doors with Self-Closing Devices	2