

**Kentucky - Office of Inspector General  
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes  
During FFY 2019 (10/01/2019 - 09/30/2020)**

**FED - K307 - K - LSC 2012 Health Existing (03.03)**

<b>Tag</b>	<b># of Citations</b>
<b>0353 - Sprinkler System - Maintenance and Testing</b>	<b>15</b>
<b>0374 - Subdivision of Building Spaces - Smoke Barrie</b>	<b>13</b>
<b>0321 - Hazardous Areas - Enclosure</b>	<b>11</b>
<b>0363 - Corridor - Doors</b>	<b>11</b>
<b>0222 - Egress Doors</b>	<b>9</b>
<b>0232 - Aisle, Corridor, or Ramp Width</b>	<b>9</b>
<b>0741 - Smoking Regulations</b>	<b>8</b>
<b>0923 - Gas Equipment - Cylinder and Container Storage</b>	<b>8</b>
<b>0920 - Electrical Equipment - Power Cords and Extens</b>	<b>7</b>
<b>0918 - Electrical Systems - Essential Electric Systems</b>	<b>5</b>