

**Kentucky - Office of Inspector General  
 Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes  
 During FFY 2020 (10/01/2022 - 09/30/2023)**

**FED - K307 - K - LSC 2012 Health Existing (03.03)**

Tag	# of Citations
0321 - Hazardous Areas - Enclosure	3
0918 - Electrical Systems - Essential Eelectrical System	3
0372 - Subdivision of Building Spaces - Smoke Barriers	2
0920 - Electrical Equipment - Power Cords and Extens	2
0222 - Egress Doors	1
0291 - Emergency Lighting	1
0293 - Exit Signage	1
0353 - Sprinkler System - Maintenance and Testing	1
0355 - Portable Fire Extinguishers	1
0781 - Portable Space Heaters	1