Kentucky - Office of Inspector General
Top 10 Federal Life Safety Code Deficiencies Cited for Nursing Homes
During FFY 2026 (10/01/2025 - 09/30/2026)

FED - K307 - K - LSC 2012 Health Existing (03.03)

Tag	# of Citations
0920 - Electrical Equipment - Power Cords and Extens	58
0372 - Subdivision of Building Spaces - Smoke Barrier	43
0353 - Sprinkler System - Maintenance and Testing	43
0363 - Corridor - Doors	30
0321 - Hazardous Areas - Enclosure	25
0918 - Electrical Systems - Essential Electrical System	22
0900 - Health Care Faciltiies Code - Other	19
0324 - Cooking Facilities	18
0916 - Electrical Systems - Essential Electrical System	18
0781 - Portable Space Heaters	17