



6801 CROSSBOW DRIVE • EAST SYRACUSE, NY USA 13057 315.437.1611

• FAX 315.437.1903 • EMAIL: FLEXHOSE@FLEXHOSE.COM

Standard Specification

(20192LUloop.docx)

RECOMMENDED ENGINEERING SPECIFICATION FOR 2-LEG V STYLE LOOP

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Two-leg U style flexible loop, model FLTL3U (+/-1.5") or FLTL8U (+/-4"), which provides a flexible pipe loop that will absorb and compensate thermal movement (X plane) or seismic movement (X, Y, Z plane) as well as reduce piping stress.
Models FLTLU3(8)M (male NPT ends)
Models FLTLU3(8)F (150# plate steel flanges)
Models FLTLU3(8)G (groove pipe ends)
Models FLTLU3(8)W (beveled weld ends)
Models FLTLU3(8)S (copper female sweat end)

1.02 MANUFACTURES

- A. Two-leg U style flexible loop shall be manufactured by Flex Hose Co. or pre-approved equal.

PART 2 PRODUCTS

2.01 2-Leg U style flexible loop

- A. Construction to be 2 equal length sections of annular corrugated 321 / 304L stainless steel (bronze for models FLTLU3(8)S) close-pitch hose (made in USA) with stainless steel (or bronze for models FLTLU3(8)S) over-braid (made in USA) that will absorb or compensate for pipe movements thermally or when used in seismic applications.
- B. The corrugated metal hose, braid(s), and a stainless steel ring-ferrule/band (material gauge not less than .048") must be integrally seal welded using a 100% circumferential, full penetration TIG welds. End fittings shall be selected per application. Fittings must be attached using a 100% circumferential TIG weld.
- C. Braided stainless steel flexible loops must be suitable for operating temperatures up to 850 degrees F (455 degrees C). Braided bronze flexible loops must be suitable for operating temperatures up to 400 degrees F (204 degrees C)
- D. Flexible loops must be designed for pressure testing to 1.5 times their maximum rated working pressure and a minimum 4:1 (burst to working) safety factor.
- E. Each braided flexible hose loop shall be individually leak tested by the manufacturer using air-under-water, helium vacuum and/or hydrostatic pressure.
- F. Flexible hose loops shall be prepared for shipment using a cut-to-length metal shipping bar, tacked securely between the elbows of the two parallel legs, to maintain the manufactured length during shipping. Shipping bar must be removed prior to system start-up.
- G. The Flex-Hose Co. hanger assembly kit shall be used to support and hang the flexible hose loop. The UL Listed Seismic Wire/Cable assemblies conform to the requirements of the ASCE (American Society of Civil Engineers) guidelines for structural applications of wire rope, in that the cable is pre-stretched and the permanent end fittings maintain the break strength of the cable with a safety factor of two.
- H. The pre-manufactured flexible loop shall be installed and guided following the manufacturer's published installation instructions. Two-leg V style manufactured loops that require pipe alignment guides (in thermal applications) shall use "Spider" type with outer housing ring affixed to building structure with rigid elements. Units shall be fabricated from carbon steel. Pipe hangers and/or roller supports shall not be considered acceptable for use as guides.

www.flexhose.com • 1.877.TRI FLEX

A world of difference in critical piping connections since 1968.™



6801 CROSSBOW DRIVE • EAST SYRACUSE, NY USA 13057 315.437.1611

• FAX 315.437.1903 • EMAIL: FLEXHOSE@FLEXHOSE.COM

Standard Specification

- I. When used for potable water (in copper tubing systems) the model FLTLU3(8)S shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with NSF/ANSI 61-2011. *SPECIAL NOTE: Drinking water supplies that are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.*
- J. When used for potable water (in copper tubing systems) the model FLTLU3(8)S shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with Section 1417(d) of the Safe Drinking Water Act. Must meet the lead content requirements of Section 116875 of the California Health & Safety Code, and the criteria of NSF/ANSI 372 for low lead.
- K. When used for potable water (in steel piping systems) the models FLTLU3(8)F, FLTLU3(8)M and FLTLU3(8)F shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with NSF/ANSI 61-2011
- L. When used for potable water (in steel piping systems) the models FLTLU3(8)F, FLTLU3(8)M and FLTLU3(8)G shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with Section 1417(d) of the Safe Drinking Water Act. Must meet the lead content requirements of Section 116875 of the California Health & Safety Code, and the criteria of NSF/ANSI 372 for low lead.
- M. When used for potable water (in stainless steel piping systems) the models FLTLU3(8)SSF6, FLTLU3(8)SSM6 and FLTLU3(8)SSG6 shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with NSF/ANSI 61-2011
- N. When used for potable water (in stainless steel piping systems) the models FLTLU3(8)SSF6, FLTLU3(8)SSM6 and FLTLU3(8)SSG6 shall be third party tested and, listed (by a laboratory in compliance with all applicable requirements of ISO/IEC 17025) and marked in accordance with Section 1417(d) of the Safe Drinking Water Act. Must meet the lead content requirements of Section 116875 of the California Health & Safety Code, and the criteria of NSF/ANSI 372 for low lead.

2.02 WARRANTY

Two-leg flexible U style loop must have a 2-year full product replacement warranty when installed in accordance with all specifications and installation instructions as described in the Two-Leg V / U style flexible loop Installation and Maintenance Instructions.

www.flexhose.com • 1.877.TRI FLEX

A world of difference in critical piping connections since 1968.™