

FEDERAL ENERGY REGULATORY COMMISSION
Office of Energy Projects
Division of Dam Safety and Inspections
Chicago Regional Office

In reply refer to: P-3409

July 24, 2025

VIA Electronic Mail

Mr. Chris Adams
Director of Mountain Experience
Boyne USA
Chris.Adams@boynemountain.com

Re: 2025 Annual Dam Safety Inspection Follow-Up
Boyne River Hydroelectric Project (FERC Project No. 3409)

Dear Mr. Adams:

The 2025 Dam Safety Inspection (DSI) of the Boyne River Hydroelectric Project, FERC No. 3409 was conducted on July 2, 2025 by Mr. Chad Blackney of FERC's Chicago Regional Office. All project structures were inspected and no dam safety deficiencies requiring immediate action were observed.

As discussed during the inspection, you recently began performing upgrades in the powerhouse, and generation is currently offline. You plan on replacing the turbine and shaft, cleaning and recoating the penstock, and upgrading the electrical relays this summer. The generation status and a summary of completed repairs should be included in the next annual DSSMR, due by **April 1, 2026**.

If there are questions regarding this letter, contact Mr. Chad Blackney, P.E. at (312) 596-4445 or at Chad.Blackney@ferc.gov or me at (312) 596-4430.

Sincerely,

KEVIN

GRIEBENOW

Digitally signed by
KEVIN GRIEBENOW
Date: 2025.07.24
08:49:30 -05'00'

Kevin Gribenow, P.E.
Regional Engineer

Document Content(s)

03409 Boyne River 2025 10-Day PIL.docx.pdf.....1