

Panel: How to Keep the Damn Lights ON

Pallas LeeVanSchaick
NYISO Market Monitoring Unit
Potomac Economics

IPPNY Conference
March 24, 2026

Resource mix changes leading to reliability risks

- Older generating units running harder in recent years
 - For 12 GW of 40+ yr-old fossil fuel units still operating in 2025:
 - Production: 14 TWh in 2025, up 84% from 2019
 - Run hours: wgt-avg of 2,525 hours in 2025, up 81% from 2019
- Time on outage is increasing for these units
 - Time on outage: wgt-avg of 2,285 hours in 2025, up 29% from 2019
- Winter reliability risks are reducing time available for outages
 - Nearly 2 GW of dual-fuel and oil-fired generation was on planned outages over the winter of 2024/25
- Nearly 2 GW of conventional generation in “harvest mode”:
 - Low capacity factors, limited maintenance, offers designed to avoid operation outside of peak load conditions

Future supply deficiency should attract investment

- In summary:
 - Older units are running more
 - Maintenance is getting more expensive, time-consuming, and frequent
 - Available months for planned outages dropping from 9 to 6 months of the year for most units
 - Capacity in “harvest mode” does not inspire confidence
- Eventually these factors will lead to significant reliability issues if new supply does not enter the market.
- In a competitive market with low barriers to entry, we should see new entry.
 - We are not seeing significant new entry.

How to facilitate new entry to maintain reliability

- Siting and permitting reform:
 - Allow new conventional generation at least for reliability
 - Clarify new entrants have a long-term path under future regulations
- Renew commitment to competitive markets:
 - Non-discriminatory pricing for capacity, and
 - Capacity demand curve that reflects new supply costs
- Deliverability test reform:
 - Replace with more granular capacity pricing
- Load interconnection planning coordination is needed:
 - STAR should report BPS impacts *before* interconnection is granted
 - IAs clearly distinguish firm v non-firm loads