

EXHIBIT I (MOU-FA20)

ASHRAE										9/25/20				
Room	Program	Social Distance Capacity	Total Cu. Ft	Total Sq. ft	OAI CFM per person	Total OAI CFM required	OAI CFM per Sq Ft Required	Total OAI CFM per Sq ft	Total OAI CFM Required	Actual CFM OAI	OAI from AHU%	Air Handler	Air Changes per Hour	Ceiling Height

Building 33 IDA B WELLS

101	COMM/ECW	29	20,160	2,016	10	290	0.12	242	532	611	31.25%	33AHU1.1	5.82	10
LL10	AAA STUDIO A	9	5,440	680	10	90	0.06	41	131	339	29.17%	33AHUB.1	12.83	8
LL11	AAA - LIVE & INSTALLED MUSIC	8	11,550	1,155	10	80	0.06	69	149	499	34.15%	33AHUB.2	7.59	10
LL18	AAA CONTROL C	6	4,560	570	7.5	45	0.06	34	79	323	29.17%	33AHUB.1	14.58	8
LL20	AAA CONTROL B	4	2,720	340	10	40	0.12	41	81	377	29.17%	33AHUB.1	28.50	8
LL28	AAA STUDIO B	4	3,192	399	10	40	0.06	24	64	230	29.17%	33AHUB.1	14.85	8
LL30	AAA - STUDIO	3	3,024	378	10	30	0.12	45	75	369	29.17%	33AHUB.1	25.10	8

Building 72 E 11th

602	THEA	9	44,352	3,168	10	90	0.18	570	660	1,077	48.71%	72AHU6B	2.99	14
202	VRF	16	22,610	1,615	10	160	0.06	97	257	771	26.14%	72DOAS	7.83	14
201	THEA	12	19,600	1,400	10	120	0.06	84	204	707	30.52%	72DOAS	7.09	14
504	THEA	4	4,290	429	5	20	0.06	26	46	146	32.53%	72AHU5A	6.27	10
511	THEA	10	9,660	966	10	100	0.06	58	158	343	33.99%	72AHU5B	6.27	10
613	THEA	6	3,465	495	7.5	45	0.06	30	75	221	35.09%	72AHU6A	10.91	7
608A	THEA - PAINTROOM	2	1,800	225	10	20	0.18	41	61	1,855	33.33%	72AHU6C	175.00	8
404	THEA	20	65,660	3,283	10	200	0.06	197	397	2,105	26.50%	72AHU4B	7.26	20
102	THEA/CLASSIC THEATRE	12	17,355	1,335	10	120	0.06	80.1	200.1	735	33.18%	72DOAS	7.66	13
108	THEA/COURTYARD THEATRE	26	35,230	2,710	10	260	0.06	162.6	422.6	1,800	34.72%	72DOAS	8.83	13
109	THEA/COURTYARD STAGE													
113	THEA/SHOP	12	30,875	2,375	10	120	0.18	427.5	547.5	976	36.94%	72DOAS	5.13	13
301	THEA	13	16,380	1,260	7.5	97.5	0.06	75.6	173.1	635	100.00%	72DOAS	2.33	13
305	THEA	11	14,625	1,125	10	110	0.06	67.5	177.5	565	100.00%	72DOAS	2.32	13
309	THEA	11	14,220	1,185	10	110	0.12	142.2	252.2	480	100.00%	72DOAS	2.03	12
507	THEA	9	9,660	966	10	90	0.06	57.96	147.96	161	33.99%	72AHU5B	2.95	10
615	THEA	8	8,220	685	5	40	0.06	41.1	81.1	378	35.09%	72AHU6A	7.86	12

Building 618 S Michigan

207	CCCX	38	51,948	3,996	7.5	285	0.06	240	525	3,142	32.22%	HU1/AHU-1, AHU-2	11.26	13
801B	FASH	12	13,090	1,309	7.5	90	0.06	79	169	450	30.65%	18AHU2	6.73	10

Building 754 S Wabash.

530	CCCX/ALL CAMPUS	83	207,900	6,930	7.5	622.5	0.06	416	1038	#VALUE!	varies	54AHU6.2	4.22	30
250	SC Maker's Space	26	65,296	4,664	10	260	0.18	840	1100	#VALUE!	varies	54AHU 2.1	6.06	14
440	SC Fitness Center	20	50,960	3,640	10	200	0.06	218	418	#VALUE!	varies	54AHU 4.1	14.56	14
314	SC Conference room	8	11,592	828	5	40	0.06	50	90	#VALUE!	varies	54AHU 6.1	7.72	14
244	SC BOARDROOM	14	23,954	1,711	7.5	105	0.06	103	208	#VALUE!	varies	54AHU 6.1	4.04	14

Building 916 S Wabash.

214	DANC/THEA	8	25,900	2,590	10	80	0.06	155	235	935	29.36%	16RTU2	7.38	10
215	DANC/THEA	7	8,107	737	10	70	0.12	88	158	460	29.36%	16RTU2	11.60	11
221	DANC/THEA	6	18,057	1,642	10	60	0.06	99	159	542	29.36%	16RTU2	6.14	11

EXHIBIT I (MOU-FA20)

					ASHRAE					9/25/20				
Room	Program	Social Distance Capacity	Total Cu. Ft	Total Sq. ft	OAI CFM per person	Total OAI CFM required	OAI CFM per Sq Ft Required	Total OAI CFM per Sq ft	Total OAI CFM Required	Actual CFM OAI	OAI from AHU%	Air Handler	Air Changes per Hour	Ceiling Height
223	DANC/THEA	6	18,057	1,642	10	60	0.06	99	159	543	29.36%	16RTU2	6.15	11
226	DANC/THEA	6	12,540	1,140	10	60	0.06	68	128	309	29.36%	16RTU2	5.03	11

Building 1104 S Wabash.

105	CCCX	41	90,797	5,341	7.5	307.5	0.06	320	628	1,880	33.17%	04AHU2.1	3.74	17
202	CTVA/IAM	18	66,150	4,725	10	180	0.12	567	747	1,587	30.30%	04AHU2.2	4.75	14
301	CTVA/IAM	12	8,352	928	7.5	90	0.06	56	146	581	29.94%	04AHU3.1	13.94	9

EXHIBIT I (MOU-FA20)

Room	Program	Social Distance Capacity	Total Cu. Ft	Total Sq. ft	ASHRAE					9/25/20				
					OAI CFM per person	Total OAI CFM required	OAI CFM per Sq Ft Required	Total OAI CFM per Sq ft	Total OAI CFM Required	Actual CFM OAI	OAI from AHU%	Air Handler	Air Changes per Hour	Ceiling Height

Building 1306 S. Michigan

300	DANC	18	18,000	1,800	10	180	0.06	108	288	975	31.65%	06RTU3E	10.27	10
102	DANC	4	9,918	1,102	10	40	0.06	66	106	437	32.24%	06RTU1	8.20	9
200	DANC	19	16,200	1,800	10	190	0.06	108	298	421	31.78%	06RTU2	4.91	9
320	DANC	1	2,016	252	10	10	0.06	15	25	89	30.17%	RTU3W	8.78	8
B103	DANC	13	11,520	1,280	10	130	0.06	77	207	226	30.19%	06RTUB	3.89	9
104	DANC	28	142,350	5,694	10	280	0.06	342	622	4,065	33.67%	06RTUTN/TS	5.09	25
202	DANC	10	8,730	970	10	100	0.06	58	158	535	31.78%	06RTU2	11.57	9

Building 1600 S State

141	CTVA/IAM	22	74,222	2,183	10	220	0.12	262	482	1,214	20.14%	1600AHU1	4.87	34
139	CTVA/IAM	11	42,735	1,295	10	110	0.18	233	343	985	20.14%	1600AHU1	6.87	33
105	CTVA/IAM	22	22,113	1,134	10	220	0.12	136	356	593	20.14%	1600AHU1	7.98	19.5
127	CTVA/IAM	17	28,611	1,683	10	170	0.12	202	372	614	20.14%	1600AHU1	6.40	17
125	CTVA/IAM	4	6,650	475	10	40	0.12	57	97	121	20.14%	1600AHU1	5.41	14
140	CTVA/IAM	22	184,782	7,107	10	220	0.12	853	1073	3,296	20.14%	1600AHU1	5.31	26
107	CTVA/IAM	10	22,748	1,034	10	100	0.12	124	224	313	20.14%	1600AHU1	4.10	22

Building 1014 S Michigan

415	MUSC - MFALAB	7	6,930	693	10	70	0.06	42	112	41	23.26%	14AHU4C	1.53	10
104	MUSC	24	27,000	2,250	10	240	0.06	135	375	1,294	36.00%	14HU1A	7.99	12
207	MUSC	12	12,580	1,258	10	120	0.06	75	195	391	27.70%	14AHU2A	6.72	10
405	MUSC	5	3,822	546	10	50	0.06	33	83	284	29.44%	14RTU4A	15.15	7
408	MUSC	1	2,040	204	10	10	0.06	12	22	165	32.43%	14RTU4B	15.00	10
411	MUSC	2	7,000	700	10	20	0.06	42	62	65	23.26%	14AHU4C	2.40	10
409	MUSC	4	4,200	420	10	40	0.06	25	65	116	23.26%	14AHU4C	7.11	10
201	MUSC/LAB	9	6,422	676	10	90	0.06	41	131	322	27.70%	14AHU2A	10.85	9.5
203	MUSC	6	6,422	676	10	60	0.06	40.56	100.56	191	27.70%	14AHU2A	6.46	9.5
205	MUSC/PL ONLY	7	5,938	625	10	70	0.06	37.5	107.5	231	27.70%	14AHU2A	8.42	9.5
211	MUSC	6	5,463	575	10	60	0.06	34.5	94.5	260	27.70%	14AHU2A	10.32	9.5
407	MUSC	1	1,600	160	5	5	0.06	9.6	14.6	42	29.44%	14RTU4A	5.29	10

Building 600 S Michigan

913	PHOT	25	14,904	1,863	7.5	187.5	0.06	112	299	509	26.93%	00AHU9B(0060)	7.61	8
1501	TV LAB	13	17,670	1,178	10	130	0.12	141	271	1,734	32.71%	00RTU1500NE	18.00	15

Building 623 S Wabash

513	SCMT	14	9,792	1,224	10	140	0.18	220	360	614	32.50%	23RTU11.1	11.57	8
705	FASH	6	30,272	2,752	10	60	0.12	330	390	668	25.21%	23AHU7	5.25	11
807A	AAH/DSGN	10	8,800	800	10	100	0.18	144	244	500	32.50%	23RTU11.1	10.49	11

Building 624 S Michigan

209	ALL CAMPUS	6	108,630	12,070	5	30	0.12	1448	1478	3,316	32.01%	2443 & 2444	5.72	9
-----	------------	---	---------	--------	---	----	------	------	------	-------	--------	-------------	------	---